



EUROVENT CERTITA CERTIFICATION

RS 4/C/001- 2015

Issued January 2015

**RATING STANDARD
for the
CERTIFICATION
of
AIR FILTERS**

RS 4/C/001- 2015

Issued January 2015
Supersedes RS/4/C/001-2014

Editing (date): Sylvain COURTEY (September 2014)
Checking (date): Jean FOURCROY (December 2014)
Approval (date): Compliance Committee for Air Filters (October 2014)
Approval (date) CPPC (6 January 2015)
Comes into effect from: 20 January 2015

Modifications as against last version:

Nb	Modifications	Section	Page
1	The definition of the filter depth has been added	III	4
2	All tests shall be done with a temperature of 23 °C +/- 5 K and a relative humidity of 40% +/- 10 %.	IV	5
3	Energy classification and labelling rules have been added	APPENDIX A	6
4	Eurovent Document 4/11 – 2013 has been replaced by Eurovent Document 4/21 – 2014 or RS 4/C/001 - 2015	Various	

This document is strictly reserved for use in the Eurovent Certification Programmes.
Reproduction or translation of any part of the document is forbidden without written
permission from Eurovent Certita Certification

Published by Eurovent Certita Certification
48-50 rue de la Victoire
75009 Paris, FRANCE

Tel: + 33 1 75 44 71 71
E-mail: a.baillau@eurovent-certification.com

TABLE OF CONTENTS

I.	PURPOSE	4
II.	SCOPE	4
III.	DEFINITIONS	4
IV.	TESTING REQUIREMENTS	5
V.	CERTIFIED CHARACTERISTICS	5
VI.	TOLERANCES	5
	APPENDIX A. ENERGY EFFICIENCY CLASSIFICATION AND LABELLING	6
	<i>A.1. Definition of the energy efficiency classes</i>	6

I. PURPOSE

The purpose of this Rating Standard is to prescribe rating procedures to be used in the Eurovent Certified Performance Programme for Air Filters in accordance with the Operational Manual OM-11.

II. SCOPE

This Programme applies to air filter elements rated and sold as “medium and fine filters M5, M6, F7 – F9” as defined in the respective valid version of EN 779:2012.

III. DEFINITIONS

Air Filter Element: A filter unit to clean air from particulate contamination comprising filter material including framing, supporting parts and gaskets, the total to be inserted into a filter housing device.

Performance Data: Single values out of the filter test report as carried out in accordance with EN 779:2012.

Filter family: A filter family is characterised by the following:

- the same filter material
- the same basic construction (e.g. bag, V-type, etc.)
- the same face velocity : rated air-flow / min. net filter area; (does not have to be published). The airflow rate shall be adapted to the face area.
- The same length/depth of the overall filter element with a tolerance of +/- 10% or 50 mm whatever is the smaller
- The same ratio of filter medium area to front face area
- the same filter class M5, M6, F7, F8 or F9
- published data available about: basic construction, filter media, filter class available via internet or other published sales brochures.

Representative Filter Element: Any type chosen by Eurovent Certita Certification out of a “filter” fitting into the EN 779:2012 – test rig.

F-Filter Class: Class of fine (group “F”) air filters based on classification according to EN 779:2012 (F7, F8 or F9).

M-Filter Class: Class of medium (group “M”) air filters based on classification according to EN 779:2012 (M5, M6).

Filter depth: overall depth of the filter including the frame (complete filter). The Filter Depth defined here (and declared in the declaration file) is not the one used to calculate the filtering area.

Initial Pressure Drop: Pressure drop of the clean filter operating at the test air flow rate.

Initial Efficiency: Efficiency of the clean filter operating at the test air flow rate.

Discharged Efficiency: Discharged efficiency of media at 0.4 µm according to EN 779:2012 clause 11.

Minimum Efficiency: Lowest efficiency among the discharged efficiency, initial efficiency and the lowest efficiency throughout the loading procedure of the test – Note: Minimum efficiency is used for the classification of F-filters (see definition in EN779:2012).

Eurovent Energy Efficiency Class: Energy Efficiency class as defined in – *Appendix A*.

Annual Energy Consumption: Estimated Electricity Consumption per year due to an air filter as defined in *Eurovent Document 4/21 - 2014* (kWh/annum).

IV. TESTING REQUIREMENTS

Verification of performance characteristics shall be carried out in accordance with:

- European Standard EN 779:2012: “Particulate air filters for general ventilation - Determination of filtration performance” for Filter Class, initial pressure drop, initial efficiency and minimum efficiency;
- *Eurovent Document 4/21 - 2014: “Calculation method for the energy use related to air filters in general ventilation systems”*

All independent laboratories have to use the same test dust producer for a given test campaign. Before each test campaign independent laboratories will inform the participants on which test dust producer will be used. Applicant (participant not yet certified) can request from Eurovent Certita Certification information on the test dust producer used during the previous test campaign.

All tests shall be done with a temperature of 23 °C +/- 5 K and a relative humidity of 40% +/- 10 %.

V. CERTIFIED CHARACTERISTICS

The following performance characteristics shall be certified:

- Filter class: M5, M6, F7 to F9
- Initial pressure drop Δp_0 in Pa, measured according to EN 779:2012
- Initial Efficiency according to EN779:2012 (for F7 to F9 filters only)
- Minimum Efficiency according to EN 779:2012 clause 11 (for F7 to F9 filters only)
- Eurovent Energy Efficiency Class according to *Appendix A* (for filters rated at 0.944 m³/s only) *is calculated from the annual energy consumption*
- Annual Energy Consumption according to *Eurovent Document 4/21 - 2014* (for filters rated at 0.944 m³/s only)

Note: If a filter rated F7, F8 or F9 is measured in a filter class lower than F7, the discharged efficiency test shall be performed (unless the manufacturer asks to not test the discharged efficiency according to OM §IV.3.c in case of a first test).

VI. TOLERANCES

When tested in the independent laboratory, the obtained results shall not differ from the claimed values by more than:

- For the filter class: as claimed or higher
- For the initial pressure drop: +(10%+Mt) or +(10 Pa + Mt) whichever largest where Mt = 5Pa (measuring tolerance as allowed by EN 779:2012)
- For the Eurovent energy efficiency class: as claimed or higher
- For initial efficiency and minimum efficiency:

The measured value shall be higher or equal to the minimum efficiency of the declared filter class as defined in EN 779:2012 and the deviation shall be within 10%-point (see examples in Table 1 hereafter).

- For the annual energy consumption: **+10%+ 60 kWh/y**

APPENDIX A. ENERGY EFFICIENCY CLASSIFICATION AND LABELLING

A.I. Definition of the energy efficiency classes

The Annual Energy Consumption calculated using the method described in Eurovent Document 4/21 - 2014 shall be compared to the class limits defined in the table below for the different energy efficiency classes to classify the filter under concern, depending of its filter class to EN 779:2012.

Table 1: Energy efficiency class limits for each filter class according to EN 779:2012 measured at 0.944 m³/s.

Filter class		M5	M6
ME		--	--
		$M_M = 250 \text{ g ASHRAE}$	
A+		0 – 450 kWh	0 – 550 kWh
A		> 450 kWh – 600 kWh	> 550 kWh – 650 kWh
B		> 600 kWh – 700 kWh	> 650 kWh – 800 kWh
C		> 700 kWh – 950 kWh	> 800 kWh – 1100 kWh
D		> 950 kWh – 1200 kWh	> 1100 kWh – 1400 kWh
E		> 1200 kWh	> 1400 kWh
Filter class	F7	F8	F9
ME	ME ≥ 35%	ME ≥ 55%	ME ≥ 70%
		$M_F = 100 \text{ g ASHRAE}$	
A+	0 – 800 kWh	0 – 1000 kWh	0 – 1250 kWh
A	> 800 kWh – 950 kWh	> 1000 kWh – 1200 kWh	> 1250 kWh – 1450 kWh
B	> 950 kWh – 1200 kWh	> 1200 kWh – 1500 kWh	> 1450 kWh – 1900 kWh
C	> 1200 kWh – 1700 kWh	> 1500 kWh – 2000 kWh	> 1900 kWh – 2600 kWh
D	> 1700 kWh – 2200 kWh	> 2000 kWh – 3000 kWh	> 2600 kWh – 4000 kWh
E	> 2200 kWh	> 3000 kWh	> 4000 kWh